

## LIGHT NAPHTHA

USES: RAW MATERIAL IN PETROCHEMICAL INDUSTRY

PROPERTY	UM	LIMITS		TEST METHOD
		Min.	Max.	
Density at 15 <sup>o</sup> C	kg/m <sup>3</sup>	-	760	SR EN ISO 12185-03 SR EN ISO 3675-02/C91:2005 ASTM D 4052-16 ASTM D 1298-12b(2017)
Distillation:	<sup>o</sup> C	35	-	SR EN ISO 3405-11 ASTM D 86-17
- initial boiling point	<sup>o</sup> C	-	185	
- final boiling point				
Composition:				
- aromatic hydrocarbons	%(v/v)	-	18	ASTM D 1319-15
- olefinic hydrocarbons	%(v/v)	-	2	SR EN 15553-07
- naphthenic and paraffinic hydrocarbons	%(v/v)	80	-	
Sulphure content	mg/kg	-	1000	ASTM D 5453-16e1
Reid vapour pressure	mmHg	-	500	SR EN 13016-1-08 ASTM D 5191-15

**Quality control:** the control is done on lot (batch).

The batch size corresponds to tank capacity, max.1000 tones for delivery in trucks and tankers and will consist of the same product type.

For each batch must to check all quality coefficients provided in standard specification of the product/type.

The product must to comply with all provided characteristics. If not, the lot is rejected.

In case of litigation, quality control will be made on samples taken in accordance with sampling procedure and hold for this case.

**Sampling procedure:** SR EN ISO 3170-2004/C91:2005/ASTM D 4057-12

Information on product classification, packing, labelling, handling, transport and storage: according to Safety Data Sheet 19V.

**The integrated Quality-Environment-Occupational Health and Safety Management System** is certified by DNV-GL according to the following standards:

- ISO 9001
- ISO 14001
- BS OHSAS 18001

The test lab is accredited by RENAR, in compliance with SR EN ISO/CEI 17025.

© **ROMPETROL REFINING SA** Unauthorized reproduction by any mean, partial or total, is prohibited.